

LAKE COUNTY DEPT. OF UTILITIES APPROVED MATERIALS – WATER

Table of Contents

Section	Page
1. <u>Pipe and Fittings – Sec. 2.01 Rules and Regs.</u>	
A. Pipe Couplings	3
B. Pipe Repair Clamps	3
C. Fittings – Full Body	3, 4
D. Manufactured Restraint Joint Pipe	4
E. Mechanical Joint Pipe	4
F. Mechanical Joint Restraint	4
G. Restrained Flange Adapter	5
H. Ductile Iron Pipe	5
2. <u>Steel Encasement Pipe – Sec. 2.05 Rules and Regs.</u>	
A. Casing Chocks	5
3. <u>Gate Valves – Sec. 2.06 Rules and Regs.</u>	
A. Resilient Wedge and OS&Y	5, 6
4. <u>Tapping Sleeves and Valves – Sec. 2.07 Rules and Regs.</u>	
A. Tapping Sleeves	6
5. <u>Valve Box – Sec. 2.09 Rules and Regs.</u>	7
6. <u>Meter Vaults – Sec. 2.10 Rules and Regs.</u>	
A. Access Hatch Doors - Non Traffic Bearing	7
B. Castings and Covers – Traffic Bearing	7
7. <u>Fire Hydrants – Sec. 2.12 Rules and Regs.</u>	
A. Hydrants	8
B. Hydrant Anchor (swivel) Tee	8
C. Concentric Reducer	8

LAKE COUNTY DEPT OF UTILITIES APPROVED MATERIALS – WATER

Manufacturer

Model Number

Size

Comments

8. Service Connections – Sec. 2.15 Rules and Regs.

A. Bronze Service Saddles	8
B. Corporation Stops	8
C. Curb Box	9
D. Curb Stops	9
E. Union Fittings/Adapters	9

9. Meters and Settings – Sec. 2.25 Rules and Regs.

A. Combination Meter	10
B. Domestic Meter	10
C. Angle Yoke Ells	10
D. Angle Yoke Valves	10, 11
E. Yoke Expansion Connector	11
F. Yoke	11
G. Frame and Cover	11
H. Meter Lid Cover	11
I. PVC Meter Vault	12

LAKE COUNTY DEPT OF UTILITIES APPROVED MATERIALS – WATER

Manufacturer

Model Number

Size

Comments

1. Pipe and Fittings – Sec. 2.01 Rules & Regs.

A: Pipe Couplings – ****Minimum 304 Stainless Steel Bolt and Nut Required****

Dresser	-253
4"-16" Nom. Size	
Hymax	- 2000 Series
4"-24" Nom. Size	Long Sleeve Available
Romac	- 501, XR501
2"-24" 501, 4"-12" XR501	
Romac	- RC-501, EC-501
4"x3", 6", 8"x6", 10", 4"x16"	
Smith Blair	- 441,442, 461, 462,
2"-16" 441, 4"-12" 461	

B. Pipe Repair Clamps

Smith Blair	- 256, 257
2"-14" Nom. Size	¾" to 2" Threaded Outlets Available

C. Fittings C110– ****Minimum 304 Stainless Steel Bolt and Nut Required****

Clow/McWayne	- Cement lined
3" to 36"	
U.S. Pipe	- Cement lined
3" to 48"	
Star	- Cement lined
2" to 54"	
Sigma	- Cement lined
3" to 24"	

LAKE COUNTY DEPT OF UTILITIES APPROVED MATERIALS – WATER

<u>Manufacturer</u>	<u>Model Number</u>
<u>Size</u>	<u>Comments</u>
Tyler/Union/Ufco	- Cement lined
2" to 48"	
<u>D. Manufactured Restraint Joint Pipe (Boltless Restraint) –</u>	
<u>**Class 53 Unless Otherwise Specified**</u>	
Clow/McWayne	- Super Lock boltless
6" to 36"	
American	- Flex Ring Pipe boltless
4" to 48"	
U.S. Pipe	-TR Flex boltless
4" to 36"	
<u>E. Mechanical Joint Pipe - **Minimum Class 53 Unless Otherwise Specified**</u>	
Clow/McWayne	
3" to 24" / 30" to 36"	
American	
4" to 48"	
US Pipe	
4" to 48"	
<u>F. Mechanical Joint Restraints – **Minimum 304 Stainless Steel Bolt and Nut Required**</u>	
Ford	- Uni-Flange – 1400 series
3" to 36"	
Ebba Iron Inc.	-1100 series
3" to 48"	
Sigma One-Lok	- SLDE
3"-36"	- 30", 36" require SIGMASEAL improved gasket

LAKE COUNTY DEPT OF UTILITIES APPROVED MATERIALS – WATER

Manufacturer

Model Number

Size

Comments

G. Restrained Flange Adapter

Ebba Iron Inc.

-2100 Series

3" to 48"

H. Ductile Iron Pipe - *Minimum Class 53 Unless Otherwise Specified*****

US Pipe

- Tyton

4" to 64"

American

- Fastite

4" to 64"

Clow/McWayne

- Tyton/Fastite

3" to 36"

2. Steel Encasement Pipe – Sec. 2.05 Rules and Regs.

A. Casing Chocks – (Stainless Steel)

Power Seal Pipeline Products – 4810

As Needed @ 10' Intervals Max.

Cascade Waterworld Mfg.

As Needed @ 10' Intervals Max.

Advance Products and Sys. I – SS1

As Needed @ 10' Intervals Max.

3. Gate Valves – Sec. 2.06 Rules and Regs.

A. Resilient Wedge and OS&Y (MJ and Flanged Ends) – *Minimum 304 Stainless Steel Bolt and Nut Required*****

Mueller

- 2361, 2362

2" to 12" / 14" to 36"

LAKE COUNTY DEPT OF UTILITIES APPROVED MATERIALS – WATER

<u>Manufacturer</u>	<u>Model Number</u>
<u>Size</u>	<u>Comments</u>
Kennedy	
2" to 16"	
American Flow Control	- 2500
2" to 16"	
Clow	
2" to 16"	

4. Tapping Sleeves and Valves – Section 2.07 Rules and Regs.

A. Tapping Sleeves

****Stainless Steel Outlets ONLY** - **15" Minimum Width****

JCM	- 439
4" to 24"	
Romac Industries	- SSTIII
4" to 30"	
Smith Blair	- 663, 665
4" to 24"	
Mueller	- 304MJ
4" to 24"	

LAKE COUNTY DEPT OF UTILITIES APPROVED MATERIALS – WATER

Manufacturer

Model Number

Size

Comments

5. Valve Box - “Water” on Lid– 3 Piece Screw Type – Sec. 2.09 Rules and Regs.

****Heavy Duty Top Section ONLY**Slotted lid ONLY****

Bingham Taylor

5.25”	Extensions available
-------	----------------------

Tyler	- 6860 Series
-------	---------------

5.25”	Extensions available
-------	----------------------

Star	- VB0006 Series
------	-----------------

5.25”	Extensions available
-------	----------------------

Sigma	-VB630
-------	--------

5.25”	Extensions available
-------	----------------------

6. Meter Vaults – Section 2.10 in Rules and Regs.

A. Access Hatch Doors for Non Traffic Bearing Applications

Bilco

B. Castings and Covers for Traffic Bearing Applications

East Jordan Iron Works	- 1710
------------------------	--------

Heavy Duty

Neenah	- Model R-1782
--------	----------------

Heavy Duty

LAKE COUNTY DEPT OF UTILITIES APPROVED MATERIALS – WATER

Manufacturer

Model Number

Size

Comments

7. Fire Hydrants – Section 2.12 in Rules and Regs.

A. Hydrants – Three Way Type - **All above and below ground bolts and nuts shall be 304 or 316 stainless steel. – All lower stems shall be 410 stainless steel.**

Mueller – Super Centurion 250 - A423

5.25" MVO

B. Hydrant Anchor (Swivel) Tees and 90's

Clow, Sigma, Star, Tyler Union, US Pipe

C. Concentric Reducer

Clow, Sigma, Star, Tyler Union, US Pipe

8. Service Connections – Section 2.15 Rules and Regs.

A. Bronze Service Saddles

Mueller - BR2B

4" to 16" Nom. Size Double Strap, ¾" to 2" Outlet

Smith Blair - 325

4" to 12" Nom. Size Double Strap, ¾" to 2" Outlet

B. Corporation Stops - **No lead/Low lead ONLY**

AY McDonald - 4701 or 4701-B - up to and including 1"

1" Min. New Construction - 4701-B – 1 ½" and 2"

Mueller - H15000 - up to and including 1"

1" Min. New Construction - B25000 - 1 ½" and 2"

Ford Meter Box Co. - F600 - up to and including 1"

1" Min. New Construction - FB600 - 1 ½" and 2"

LAKE COUNTY DEPT OF UTILITIES APPROVED MATERIALS – WATER

<u>Manufacturer</u>	<u>Model Number</u>
<u>Size</u>	<u>Comments</u>

C. Curb Box

McWayne Bibby	-V005-V011
2.5" Diameter	Screw Type
Bingham and Taylor	- P-94-E
2.5" Diameter	Screw Type
Sigma	- VB794E
2.5" Diameter	

D. Curb Stops – ¼ Turn Only - **No lead/Low lead ONLY**

AY McDonald	- 76100
1" Min. New Construction	
Mueller	- B-25204
1" Min. New Construction	
Ford Meter Box Co.	- B-22 Series
1" Min. New Construction	

E. Union Fittings / Adapters - **No lead/Low lead ONLY**

Mueller	- H-15400
1" Min. New Construction	- P-15403 – Customer Side ONLY
AY McDonald	- 4758
1" Min. New Construction	
Ford Meter Box Co.	- C22 Series
1" Min. New Construction	- C44 – Customer Side ONLY

LAKE COUNTY DEPT OF UTILITIES APPROVED MATERIALS – WATER

Manufacturer

Model Number

Size

Comments

9. Meters and Settings – Section 2.25 in Rules and Regs.

A. Combination Meter – Remote Read

Sensus - Omni F2

4" and Above

Octave - Ultrasonic

2" to 12"

B. Domestic Meter – Remote Read

Master Meter - Multi Jet

1" to 2"

Sensus - Omni C2 or T2

1 ½" and 2"

C. Angle Yoke Ells - **No lead/Low lead ONLY******

Ford - L92 Series

¾" to 1"

Mueller - H-14202

¾" to 1"

AY McDonald - 4779Y

¾" to 1"

D. Angle Yoke Valve - **No lead/Low lead ONLY******

AY McDonald - 4602Y

¾" to 1" - 4602BY

Ford - AV92 Series

¾" to 1" - BA92 Series

LAKE COUNTY DEPT OF UTILITIES APPROVED MATERIALS – WATER

<u>Manufacturer</u>	<u>Model Number</u>
<u>Size</u>	<u>Comments</u>
Mueller	- H14264
¾" to 1"	- B24264

E. Yoke Expansion Connector - **No lead/Low lead ONLY**

AY McDonald	- 14-2 EHG, 14-4 EHG
¾" / 1"	
Mueller	- H-14234
¾" / 1"	3 piece with O-ring
Ford	- EC-23, EC-4
¾" / 1"	

F. Yoke

AY McDonald	-14-2 / 14-4
¾" / 1"	
Mueller	- H-5020 / H-5040
¾" / 1"	
Ford	- Y-502 / Y-504
¾" / 1"	

G. Frame and Cover

East Jordan	- 2890
	Non Traffic Bearing

H. Meter Lid Cover

Ford	C-32-T, C3-T, C4-T
18" to 24" Diameter	

LAKE COUNTY DEPT OF UTILITIES APPROVED MATERIALS – WATER

Manufacturer

Model Number

Size

Comments

I. PVC Meter Vault 30" Depth

Carson / Sonoloc / ADS

18" through 30" Diameter

PVC Meter Vault
